

SKG-IKOB PRODUCTCERTIFICATE

637.862.01

Date of issue: 23-05-2024



Certificate holder

GIESSE S.p.A.
Via Tubertini 1
I-40054 Budrio (BO)
T: +39 51 8850677
E: infotechgiesse@schlegel.com
I: www.giesse.it



Declaration of SKG-IKOB

This certificate has been issued on the basis of BRL 3104 in accordance with the SKG-IKOB Regulations for Attestation, Certification and Inspection.

SKG-IKOB declares that the by or on behalf of the certificate owner produced building hardware product:

window handle

delivered under logo / brand:

Reguitti

delivered under type- and / or article number:

System DK DW1

meets class 2 STER according BRL 3104 and NEN 5089: 2009 if the product is indelibly marked with the SKG mark, as shown above.

For SKG-IKOB

A blue ink handwritten signature, appearing to be "H.A.J. van Dartel", written over a horizontal line.

ir. H.A.J. van Dartel
Certification manager

Verify at www.sterrenwijzer.nl if this certificate is still valid and actual.
This certificate contains 2 pages.

CERTIFICATE

SKG-IKOB Certificatie
Poppenbouwing 56
4191 NZ Geldermalsen

Postbus 202
4190 CE Geldermalsen

T 088-2440100
info@skgikob.nl
www.skgikob.nl

SKG-IKOB PRODUCTCERTIFICATE

GIESSE S.p.A.
Number: 637.862.01

page 2 of 2

1. PRODUCT
window handle

PRODUCT TYPE
window handle

2. TECHNICAL SPECIFICATION

Operating:	Mechanical operation
Construction:	1 handle with spindle
System:	locking by cylinder support: oval OR square various handles
Material:	support: steel zinc coated i.c.m. stainless steel cover handle: stainless steel spindle: steel zinc coated
Dimension:	support: 65x30x12 mm spindle: square. 7/7 mm x various length
Fixing:	2xM5
Intended use:	PVC, metal, window-inward-opening, window-outward-opening for windows in combination with mortice bolts

3. DELIVERY

The preconditions for correct installation and the fasteners to be used are described in the enclosed or digitally published installation instructions with the following version:
RZJ0MZJDW1XXXXXXXX_T - REV 01

4. PERFORMANCES

A window handle according to this certificate fulfils the relevant requirements of BRL 3104.

A window- or door set, in which this window handle is installed according to the installation instructions of the certificate holder meets at least burglar resistance class (RC) 2 of NEN 5096 and EN 1627, if:

the façade element or the (profile-)system from which the element is manufactured is delivered under a (KOMO-)quality approval with respect to the aspect burglar resistance, in which the actual window or door type is admitted and the herein mentioned conditions are fulfilled.

A window or door, in existing buildings, in which this window handle is installed according to the installation instructions of the certificate holder, meets the requirements of the Police Mark Save Housing (PKVW) - Existing Building, if:

the other aspects of the façade element also comply with the applicable PKVW Protection directive (publication CCV).
